



UNBRACED POLE

BRACED STRUCTURE

4" x 6" x 20'

NOTES:

1. TEMPORARY SERVICE STRUCTURES SHALL WITHSTAND THE STRESSES OF SERVICE WIRES AND ATTACHED EQUIPMENT.
 2. SERVICE STRUCTURES SHALL BE WITHIN 75' OF THE COOPERATIVE POLE TO WHICH SERVICE IS TO BE CONNECTED.
 3. A MIN. CLEARANCE OF 18' SHALL BE MAINTAINED OVER DRIVEWAYS, STREETS, ALLEYS AND AREAS ACCESSIBLE TO MOTOR VEHICLES, (22' OVER STATE HWYS.) A MINIMUM CLEARANCE OF 12' SHALL BE MAINTAINED OVER SIDEWALKS AND LAWNS.
 4. METER HEIGHT, GROUNDING, CLEARANCES, AND WIRING SPECIFICATIONS TO BE THE SAME AS FOR ANY PERMANENT SERVICE.
 5. THE COOPERATIVE RESERVES THE RIGHT NOT TO CONNECT ANY TEMPORARY SERVICE IF THE COOPERATIVE DOES NOT CONSIDER THE INSTALLATION TO BE ADEQUATE.
 6. A 4"x6" UNBRACED TIMBER IS REQUIRED BY SOME LOCAL AUTHORITIES.
 7. THE COOPERATIVE FURNISHES AND INSTALLS METER, SERVICE DROP CONDUCTORS AND ATTACHMENT, AND MAKES CONNECTIONS OF SERVICE ENTRANCE WIRES TO SERVICE DROP WIRES.
 8. MEMBER SHALL FURNISH AND INSTALL POLE OR STRUCTURE, SERVICE ENTRANCE CABLE AND RACEWAY, DISCONNECT DEVICE AND GROUNDING.
 9. METER SOCKET IS FURNISHED BY THE COOPERATIVE AND INSTALLED BY MEMBER.
- A. 100 AMP installation: 1½" conduit & nipple, minimum #2 AWG copper conductor.
 200 AMP installation: 2" conduit & nipple, minimum #3/0 AWG copper conduit.

TEMPORARY SERVICE
FROM OVERHEAD LINE